

TABLE 1

**Drinking Water Sampling for Lead Content
Lexington Community Unit School District #7
Lexington Elementary School
Sampled: November 14, 2017**

Sample ID	Location	Water Source	Results (ppb)
01	Kitchen 3-Bay (left)	Sink	3.8
01A	Kitchen 3-Bay (left)	Sink	3.6
02	Kitchen 3-Bay (right)	Sink	2.2
02A	Kitchen 3-Bay (right)	Sink	1.9
02B	Kitchen 3-Bay (right)	Sink	2.9
03	Ice Machine	Other	<1.0
04	Main Hallway by Restrooms (left)	Fountain	<1.0
04A	Main Hallway by Restrooms (left)	Fountain	<1.0
05	Main Hallway by Restrooms (right)	Fountain	<1.0
05A	Main Hallway by Restrooms (right)	Fountain	<1.0
06	Room 189	Fountain	<1.0
06A	Room 189	Fountain	<1.0
07	Room 189	Sink	4.2
07A	Room 189	Sink	1.5
08	Hallway by Room 182 (left)	Fountain	<1.0
08A	Hallway by Room 182 (left)	Fountain	<1.0
09	Hallway by Room 182 (right)	Fountain	<1.0
09A	Hallway by Room 182 (right)	Fountain	<1.0
10	Gymnasium	Fountain	1.2
10A	Gymnasium	Fountain	1.4
11	Hallway by Room 119 (left)	Fountain	<1.0
11A	Hallway by Room 119 (left)	Fountain	14.1
12	Hallway by Room 119 (right)	Fountain	<1.0
12A	Hallway by Room 119 (right)	Fountain	3.0

A/B Samples were precautionary samples collected at 30 seconds following the “first draw” samples (A) and 3 minutes following the A sample (B).



Water sources in excess of 20 ppb. Recommendation is to remove from service immediately. Do not return to service until re-testing confirms mitigation was effective.



Water source is < 20 ppb, but still displays evidence of lead. Recommendation is to re-test source on an annual basis at a minimum